

CAPE MAY COUNTY
DEPARTMENT of PUBLIC WORKS
Office of the COUNTY ENGINEER



DANIEL BEYEL
Freeholder

4 Moore Road
Cape May Court House, N.J. 08210-1601
(609) 465-1035 ☐ Fax: 465-1418

DALE M. FOSTER
Engineer

December 6, 2011

Memo To: Prospective Bidders

From: Dale M. Foster, PE, County Engineer

Re: **NEW JERSEY AVENUE (CR621) RESURFACING IMPROVEMENTS
FROM CRESSE AVENUE TO YOUNGS AVENUE
IN THE CITY OF WILDWOOD
CAPE MAY COUNTY, NJ
ADDENDUM NO. 2**

Addendum No. 2 has been issued to the Contract Documents for the referenced project. The revision listed shall be made to the Contract Documents issued for the receipt of bids. This addendum shall become part of the total contract.

Please note that Addendum No. 2 changes the receipt of bids from 2:00 P.M., Wednesday, December 14, 2011, to **2:00 P.M., Tuesday, December 20, 2011.**

The Bidder shall acknowledge receipt of this Addendum by signing and returning the attached acknowledgement sheet with the Bidder's Proposal.

The County regrets any inconvenience that this Addendum causes.

DMF/df
Enclosures

Cc: Stephen O'Connor, Clerk/Administrator
Purchasing Department

ADDENDUM NO. 2

The addendum listed below shall become part of the contract, due consideration to these clarifications shall be made by the Contractor in preparing their bid for the project. The Contractor shall acknowledge receipt of this Clarification by signing and returning the attached sheet with the Contractor's Proposal. Proposals not including a signed copy of the attached sheet will not be considered.

THE FOLLOWING CHANGES SHALL BE MADE TO THE ADVERTISEMENT FOR BIDS:

The first paragraph of the Advertisement for Bids is revised to read as follows:

Notice is hereby given that sealed proposals addressed to Stephen O'Connor, County Administrator, will be received up to **2:00 p.m.** prevailing time, on **Tuesday, December 20, 2011**, at which time they will be publicly opened and read at the William E. Sturm, Jr. Administration Building, 4 Moore Road, Crest Haven Complex, Cape May Court House, New Jersey, for the following:

“NEW JERSEY AVENUE (CR 621) RESURFACING IMPROVEMENTS FROM CRESSE AVENUE TO YOUNGS AVENUE IN THE CITY OF WILDWOOD”

THE FOLLOWING CHANGES SHALL BE MADE TO THE PROPOSAL:

Page P3 of 5 of the Proposal, the following Item No. is revised to read as follows:

Item No.	Description	Unit	Contract Quantity	Unit Price	Amount
57	Foundations, Type MC	Unit	2		

New proposal page, Pages P3R of 5, dated December 6, 2011, is attached and shall be substituted for the page provided with the Proposal.

THE FOLLOWING CHANGES SHALL BE MADE TO THE SPECIAL PROVISIONS:

Subsection 701.04 MEASUREMENT AND PAYMENT: *The seventh item is revised to read as follows:*

<i>Item</i>	<i>Pay Unit</i>
FOUNDATIONS, TYPE MC	UNIT

THE FOLLOWING CHANGES SHALL BE MADE TO THE PLANS:

Sheet 2: *The Title of Pay Item 57 is revised to read: "FOUNDATIONS, TYPE MC"
The Contract Quantity and Plan Quantity are revised to read: "2"*

Sheets 36 thru 42:

Note 2 is revised to read as follows:

"2. WHEN CONSTRUCTION REQUIRES THE EXISTING TRAFFIC SIGNAL SYSTEM BE PLACED IN FLASHING OPERATION OR WHEN THE CONTROLLER FOUNDATIONS ARE BEING REPLACED, THE SIDE

STREET APPROACHES TO NEW JERSEY AVENUE ARE TO BE CONTROLLED BY BARRICADE-MOUNTED STOP SIGNS. REFER TO THE DETOUR PLANS AND TRAFFIC CONTROL DETAILS.”

Note 4 is revised to read as follows:

“4. ALL EXISTING JUNCTION BOXES IN CONCRETE FOUNDATIONS ARE TO BE REMOVED AS PART OF THIS CONTRACT. EXISTING TRAFFIC SIGNAL CONDUITS SHALL BE REMOVED IF PRACTICAL OR ABANDONED IN PLACE. REMOVAL OF JUNCTION BOXES, CONDUITS AND FOUNDATIONS WHERE APPLICABLE, ARE PAYABLE UNDER THE PAY ITEM FOR THE CORRESPONDING NEW WORK.”

The following Notes are added:

“6. THE 17” X 30” JUNCTION BOXES SHALL BE A MINIMUM OF 42 INCHES DEEP TO PERMIT THE INSTALLATION OF RIGID NONMETALLIC CONDUIT TO BE INSTALLED AT A MINIMUM DEPTH OF 30 INCHES BELOW THE ROADWAY SURFACE.

7. ALL TRAFFIC SIGNAL WORK IS TO BE COORDINATED WITH THE CAPE MAY COUNTY ENGINEERS OFFICE AND THE COUNTY TRAFFIC SIGNAL DIVISION.”

Sheets 36: *Eliminate the following callout in the plan view:*

CONSTRUCT: NEW CONTROLLER FOUNDATION AT
LOCATION OF EXISTING CONTROLLER
USING EXISTING ELECTRICAL SERVICE
CONSTRUCT: FOUNDATION, TYPE 1M-MC, 1 UNIT

Sheets 37: *The controller foundation callout in the plan view is revised to read as follows:*

“**CONSTRUCT:** NEW CONTROLLER FOUNDATION, TYPE MC, 1 UNIT, AT
LOCATION OF EXISTING CONTROLLER
USING EXISTING ELECTRICAL SERVICE”

Sheets 38: *Eliminate the following callout in the plan view:*

CONSTRUCT: NEW CONTROLLER FOUNDATION AT
LOCATION OF EXISTING CONTROLLER
USING EXISTING ELECTRICAL SERVICE
CONSTRUCT: FOUNDATION, TYPE 1M-MC, 1 UNIT

Sheets 39: *The controller foundation callout in the plan view is revised to read as follows:*

“**CONSTRUCT:** NEW CONTROLLER FOUNDATION, TYPE MC, 1 UNIT,
USING EXISTING ELECTRICAL SERVICE”

Sheets 40 thru 42: *Eliminate the following callout in the plan view:*

CONSTRUCT: NEW CONTROLLER FOUNDATION AT
LOCATION OF EXISTING CONTROLLER
USING EXISTING ELECTRICAL SERVICE
CONSTRUCT: FOUNDATION, TYPE 1M-MC, 1 UNIT

STEPHEN O'CONNOR,
CLERK/ADMINISTRATOR

DANIEL BEYEL,
FREEHOLDER DIRECTOR

PROPOSAL (Continued)

Item No.	DESCRIPTION	Unit Measure	Quantity	Unit Price \$	Amount \$
38	STONE MULCHING, 2" THICK	SY	100		
39	SHREDDED HARDWOOD MULCHING, 2" THICK	SY	400		
40	CONSTRUCTION SIGNS	SF	1,303		
41	NO ITEM	-	-		
42	TRAFFIC CONE	UNIT	200		
43	DRUM	UNIT	136		
44	BREAKAWAY BARRICADE	UNIT	87		
45	TRAFFIC DIRECTOR, FLAGGER	HOUR	320		
46	TEMPORARY TRAFFIC STRIPES, 4"	LF	24,000		
47	RESTORATION	LS	1		
48	OIL ONLY EMERGENCY SPILL KIT, TYPE 1	LS	1		
49	CONCRETE WASHOUT FACILITY	LS	1		
50	REMOVAL OF TRAFFIC MARKINGS	LF	490		
51	2" RIGID NONMETALLIC CONDUIT	LF	60		
52	3" RIGID NONMETALLIC CONDUIT	LF	1,770		
53	17" X 30" JUNCTION BOXES	UNIT	28		
54	FOUNDATIONS, TYPE SFT	UNIT	3		
55	FOUNDATIONS, TYPE SPF	UNIT	4		
56	FOUNDATIONS, TYPE SFK	UNIT	1		
57	FOUNDATIONS, TYPE MC	UNIT	2		
58	NO ITEM	-	-		
59	NO ITEM	-	-		
60	NO ITEM	-	-		
61	NO ITEM	-	-		
62	NO ITEM	-	-		

Date _____

Firm Name of Bidder

ADDENDUM NO. 2 ACKNOWLEDGEMENT

Acknowledgement is hereby made of Addendum No. 2, issued on December 6, 2011, received since the issuance of the Contract Documents for **NEW JERSEY AVENUE (CR621) RESURFACING IMPROVEMENTS FROM CRESSE AVENUE TO YOUNGS AVENUE IN THE CITY OF WILDWOOD, CAPE MAY COUNTY, NJ.** The Contractor shall include this signed sheet with his bid package.

Signature of Bidder: _____

Title: _____

Name of Firm: _____

Address: _____

Date: _____